

Serving Those Who Serve



2024 Water Quality Report

Eglin AFB- West Housing

PWS# 1460828

American States Utility Services, Inc.

Providing the integral services that empower our nation's military communities from the ground up.



Table of Contents

Dedicated to Delivering Clean Water	3
Important Information About Your Water	4
Your Drinking Water Source	4
Source Water Assessment	4
What the EPA Wants You to Know	4
Lead in Home Plumbing	4
Substances That Could Be in Your Water	5
Lead Service Line Inventory	6
2024 Water Quality Results	7-9
PFAS and UCMR 5	10
Definitions	11

Dedicated to Delivering Clean Water

Every day, people depend on American States Utility Services, Inc. (ASUS) for the water that enhances their quality of life. We operate and maintain water and wastewater systems on military bases across the country, dedicating ourselves to producing drinking water that meets all state and federal standards and continually striving to adopt new methods for delivering the best quality drinking water to the military installations we serve. As new challenges to drinking water safety emerge, we remain vigilant in meeting the goals of source water protection, water conservation, and community education, while continuing to meet the needs of all of our water users.

ASUS is the sole provider of your water service. Our certified operators ensure the safe delivery of all potable water, taking water samples at approved sites to ensure its quality throughout our system. With a deep commitment to customer care, ASUS works diligently to protect every drop of water. As a utility provider, we constantly analyze our systems to determine which areas might need repair, replacement, or even supplementary facilities. ASUS also puts a strong focus on water efficiency, actively providing educational outreach for customers to further encourage better resource management.


We at ASUS are proud to be able to provide our services to the military personnel, civilians, and family members who live and work at Eglin Air Force Base Ranger Camp. We're honored to support the role your military installation plays in defending the country, both at home and abroad. We achieve this goal by always putting our fundamental ideals into practice. We pay special attention to the ultimate measure of success: our customer's peace of mind.

In order to maintain a safe and dependable water supply, we sometimes need to make improvements that will benefit all our customers. These improvements are sometimes reflected as rate structure adjustments. With our own team's deeply-rooted military background, we have an intimate understanding of what it takes to make an installation thrive, and we take pride in delivering unparalleled care in this regard.

We are pleased to present you with this annual water quality report and thank you for allowing us to serve you and your family. Please remember that we are always available to assist you should you ever have any questions or concerns about your water. For more details, you can view our past and current Water Quality Reports at www.asusinc.com.

Sincerely,

Eric Jenkins
Utility Manager
ASUS- Eglin AFB Ranger Camp



Franklin Jones
Director of Operations
American States Utility Services



Important Information about Your Water

What the EPA Wants You To Know

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons, such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk for infections.

These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline at (800) 426-4791.

Lead in Home Plumbing

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. ASUS is responsible for providing high-quality drinking water but cannot control the variety of materials used in plumbing components.

When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in your drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or www.epa.gov/safewater/lead.

Your Drinking Water Source

Our water source is ground water from ten wells. The wells draw from the Floridan Aquifer.

Because of the excellent quality of our water, the only treatments required are chlorine for disinfection purposes and fluoride for dental health purposes.

Source Water Assessment

In 2024, the Florida Department of Environmental Protection performed a Source Water Assessment on our system. The assessment was conducted to provide information about any potential sources of contamination in the vicinity of our wells.

There is 18 potential sources of contamination identified for this system with low-moderate susceptibility levels.

The assessment results are available on the FDEP SWAPP website at <http://www.dep.state.fl.us/swapp/> or they can be obtained from by visiting 15663 Range Road, Eglin AFB, Florida 32542 or by calling (850) 389-8773.

Important Information about Your Water

Substances That Could Be in Your Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

To ensure that tap water is safe to drink, the U.S. EPA prescribes regulations, which limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling EPA's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

Radioactive contaminants, which can be naturally occurring or a result of oil and gas production and mining activities.


Lead Service Line Inventory

EPA published the Lead and Copper Rule Revisions (LCRR) in January 2021, which requires all Community Water Systems (CWS) and Non-Transient Non-Community Water Systems (NTNCWS) to submit an initial service line inventory to the Primacy Agency by October 16, 2024. Water systems must develop an inventory to identify the material(s) of service lines connected to the public water distribution system and categorize the service line materials as “Lead”, “Galvanized Requiring Replacement (GRR)”, “Non-lead”, or “Lead Status Unknown”. Additionally, there are certain requirements for the water systems to make their information publicly accessible and to notify all persons served by the water system at the service connection with a lead, GRR, or lead status unknown service line.

ASUS has begun an effort to identify, inventory and replace any water system service lines composed of lead or having lead components. This effort is in response to updated legislation regarding the Lead and Copper Rule Revisions (LCRR).

There are currently two important ASUS websites available to the public that show the efforts made at Eglin AFB and other ASUS installations used to detect and replace these lead components in our water system. These are updated in real time with our progress and are accessible at the following hyperlinks. Please note that each website will need to be filtered to the exact installation.

The first website is the **ASUS Public Lead Service Line Inventory Dashboard** (top photo). This website shows the overview of the progress completed by ASUS. This website may be accessed at the following link: <https://asusinc.maps.arcgis.com/apps/dashboards/7f67012b51a74cb8b509978871978ea3>. The second is the **ASUS Lead Service Line Viewer** (bottom photo) that shows, by installation, the exact location and information for all service lines on the installation. This website may be accessed at the following link: <https://asusinc.maps.arcgis.com/apps/webappviewer/index.html?id=7f0b7f379b374db0b8d9adf8a93c099e>



2024 Water Quality Test Results

Eglin AFB- West Housing routinely monitors for contaminants in your drinking water according to Federal and State laws, rules, and regulations. Except where indicated otherwise, this report is based on the results of our monitoring for the period of January 1 to December 31, 2024. Data obtained before January 1, 2024, and presented in this report is from the most recent testing done in accordance with the laws, rules, and regulations.

We are pleased to report that our drinking water meets or exceeds all federal and state requirements.

Radioactive Contaminants

Contaminant and Unit of Measurement	Dates of sampling	MCL Violation (Yes or no)	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
Radium 226 + 228 or combined radium (pCi/L)	2023	No	1.1	0.5-1.1	0	5	Erosion of natural deposits
Radium 226 + 228 or combined radium (pCi/L)	2024	No	0.6	ND-0.6	0	5	Erosion of natural deposits

Secondary Contaminants

Contaminant and Unit of Measurement	Dates of Sampling	MCL Violation (yes or no)	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
Odor	2024	Yes	4	ND-4	N/A	3	Naturally occurring organics

In 2024, our water system was in violation of the Secondary MCL for the Secondary Contaminant (Non-health Based) Odor. The levels of odor are shown in the Secondary Contaminants Table. Because there were no complaints received, no further action was required.

2024 Water Quality Test Results

Inorganic Contaminants

Contaminant and Unit of Measurement	Dates of Sampling (mo/yr)	MCL Violation (Yes or no)	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
Barium (ppm)	2023	No	0.018	0.0064-0.018	2	2	Discharges of drilling wastes; discharge from metal refineries; erosion of natural deposits
Beryllium (ppb)	2023	No	0.9	ND- 0.9	4	4	Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries
Fluoride (ppm)	2023	No	0.83	0.086-0.83	4	4	Erosion of natural deposits; discharge from fertilizer and aluminum factories. Water additive which promotes strong teeth when at the optimum level of 0.7 ppm.
Lead (ppb)	2023	No	1.7	ND-1.7	0	15	Erosion of natural deposits
Nickel (ppb)	2023	No	4	ND- 4	N/A	100	Pollution from mining and refining operations. Natural occurrence in soil
Sodium (ppm)	2023	No	61	11-61	N/A	160	Salt water intrusion, leaching from soil

2024 Water Quality Test Results

Stage 1 and Stage 2 Disinfectants and Disinfection By-Products

Disinfectant of Contaminant and Unit of Measurement	Dates of sampling	MCL or MRDL Violation (Yes or no)	Level Detected	Range of Results	MCLG or MRDLG	MCL or MRDL	Likely Source of Contamination
Chlorine (ppm)	2024	No	0.76	0.52-1.0	MRDLG = 4	MRDL = 80	Water additive used to control microbes
HAA5	2024	No	1.8	N/A	N/A	60	By-product of drinking water disinfection
TTHM	2024	No	13.6	N/A	N/A	80	By-product of drinking water disinfection

Lead and Copper (Tap Water)

Contaminants and Unit of Measurement	Dates of Sampling	AL Exceeded (Yes or no)	90th Percentile Result	No. of Sampling Sites Exceeding the AL	Range of Tap Sample Results	MCLG	AL (Action Level)	Likely Source of Contamination
Copper (tap water) (ppm)	2023	No	0.1	0 of 23	ND-0.184	1.3	1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead (tap water) (ppb)	2023	No	3.1	1 of 23	ND-7.0	0	15	Corrosion of household plumbing systems and service lines connecting buildings to water mains; erosion of natural deposits

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. ASUS is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula.

Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact ASUS at 850-389-8773. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

Unregulated Contaminants (UCMR 5)

The Environmental Protection Agency (EPA) uses the Unregulated Contaminant Monitoring Rule (UCMR) to collect data for contaminants that are suspected to be present in drinking water and do not have health-based standards set under the Safe Drinking Water Act (SDWA). The list of chemical contaminants below were the focus of this round of sampling. UCMR 5 results reported at or above those MRLs should be interpreted accordingly. The detection of a UCMR 5 contaminant does not represent cause for concern, in and of itself. Reference concentrations are health-based and provide context for the detection of a UCMR contaminant. They do not represent regulatory limits or action levels and should not be interpreted as an indication that the Agency (EPA) intends to establish a future drinking water regulation.

The Eglin West Housing PWS UCMR 5 sample results from the 2024 sampling events can be found here: <https://www.asusinc.com/water-quality-reports/>.

Corrosion of pipes, plumbing fittings and fixtures may cause metals, including lead and copper, to enter drinking water. To assess corrosion of lead and copper, [name of system] conducts tap sampling for lead and copper at selected sites [insert frequency at which system conducts tap sampling]. The most recent set of lead and copper tap sampling is available for review. To view the lead and copper tap sampling data, contact ASUS at 850-389-8773 or visit:

[https://depeds.deps.state.fl.us:443/Oculus/servlet/shell?command=getEntity&\[guid=32.1587348.1\]&\[profile=Sampling\]](https://depeds.deps.state.fl.us:443/Oculus/servlet/shell?command=getEntity&[guid=32.1587348.1]&[profile=Sampling])

Contaminate	Sample Dates	Highest Level Detected	MRL (ug/L)	Units
Lithium	4/16/2024, 10/14/2024	16	9	ug/L

PFAS

In December 2021, the U.S. EPA set up mandatory sampling for many water systems to monitor for PFAS (per- and polyfluoroalkyl) substances in order to establish baseline levels of these forever chemicals found in the environment. Since 2021, these chemicals have been sampled and studied nationwide to create applicable drinking water standards that will limit the maximum amount of PFAS chemicals allowed in the water supply.

These chemicals originate from commercial and industrial sources that include many materials manufactured using “non-stick”, “waterproof”, and “stain-resistant” labeling. On military installations, the major source of this contamination is contributed to the use of Aqueous Film Forming Foam (AFFF) associated with extinguishing fires, specifically on flight lines.

ASUS conducted sampling in their system for PFAS chemicals at Eglin West-Housing and all analytes were returned as “Non-Detect”. Only PFAS chemicals that were detected are recorded in the results.

DEFINITIONS

AL (Action Level): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

MCL (Maximum Contaminant Level): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MCLG (Maximum Contaminant Level Goal): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MRDL (Maximum Residual Disinfectant Level): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MRDLG (Maximum Residual Disinfectant Level Goal): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

ND (Not detected): Indicates that the substance was not found by laboratory analysis.

Part per billion (ppb) or Microgram per liter: One part by weight of analyte to one billion parts by weight of the water sample.

Part per million (ppm) or Milligram per liter: One part by weight of analyte to one million parts by weight of the water sample.

Picocurie per liter (pCi/l): Measure of radioactivity in water.

Questions?

We encourage our valued customers to be informed about their water. If you have questions or concerns about decisions affecting your drinking water quality, please contact Amy Sweeney, Environmental Program Administrator for ASUS - Eglin AFB, at (850) 503-2241.